

REVISIONS		
REV #	DATE	BY:

LIGHTING PLAN

L6.01

LIGHTING PLAN DEVELOPED BY WLS LIGHTING. PLEASE CONTACT KEN BRONSTAD AT 817-840-9332 (DIRECT), 817-291-9421 (CELL), OR KBRONSTAD@WLSLIGHTING.COM FOR QUESTIONS.




Calculation Summary								
Label	Units	Avg	Max	Min	Avg/Min	Max/Min	PtSpcLr	PtSpcTb
FRONT	Fc	4.02	13.1	2.0	2.01	6.55	10	10
REAR	Fc	6.85	11.9	4.4	1.56	2.70		

Luminaire Schedule							
WLS13878		STRICKLAND BROTHERS	DAWSONVILLE, GA	PM: KEN	PLEASE EMAIL US FOR PRICING AT KBRONSTAD@WLSLIGHTING.COM		
Symbol	Qty	Label	Lum. Lumens	LLF	Description	Lum. Watts	
	1	A	14937	0.950	WL-CLA-N-15L-T5W-SLW 25' MOUNTING HEIGHT	92	
	1	B	11900	0.950	WLS-CLA-N-15L-T4-S215-SLW 25' MOUNTING HEIGHT	97	
	2	C	11799	0.950	WLS-CLA-N-15L-T2-S215-SLW 25' MOUNTING HEIGHT	97	
	4	D	6727	0.950	WLS-NCT-A-WM-T3-7L-40K-SLW 12' MOUNTING HEIGHT	46.4	

BASED ON THE INFORMATION PROVIDED, ALL DIMENSIONS AND LUMINAIRE LOCATIONS SHOWN REPRESENT RECOMMENDED POSITIONS. THE ENGINEER AND/OR ARCHITECT MUST DETERMINE APPLICABILITY OF THE LAYOUT TO EXISTING OR FUTURE FIELD CONDITIONS.

THIS LIGHTING PATTERN REPRESENTS ILLUMINATION LEVELS CALCULATED FROM LABORATORY DATA TAKEN UNDER CONTROLLED CONDITIONS UTILIZING CURRENT INDUSTRY STANDARD LAMP RATINGS IN ACCORDANCE WITH ILLUMINATING ENGINEERING SOCIETY APPROVED METHODS. ACTUAL PERFORMANCE OF ANY MANUFACTURER'S LUMINAIRE MAY VARY DUE TO VARIATION IN ELECTRICAL VOLTAGE, TOLERANCE IN LAMPS AND OTHER VARIABLE FIELD CONDITIONS.



6820 CORPORATION PKWY
FORT WORTH, TX 76126
WWW.WLSLIGHTING.COM

STRICKLAND BROTHERS
DAWSONVILLE, GA